

## TECHNICAL STANDARDS and SAFETY AUTHORITY

345 Carlingview Drive Toronto, Ontario M9W 6N9 Toll free 1-877-682-8772 www.tssa.org

INSPECTION DETAILS
Date of Inspection: Oct 13, 2021

Reference No.: 64890482

Building Type: OFFICE

Equipment:

Total Hours: 1.75 (Travel time not included)

Type: Periodic Inspection (Elevating Devices)

Passenger Elevator

## **Inspection Report**

Report No.: 9010133 Report Date: Oct 14, 2021

Inspector: Gilmet, William Phone: 647-459-9665 Email: wgilmet@tssa.org

**INSPECTION LOCATION:** 

WOODWARD WASTEWATER TREATMENT PLANT 700 WOODWARD AVE

HAMILTON L8H 6P4

INSPECTION CUSTOMER: CITY OF HAMILTON 71 MAIN ST W

3RD FLOOR, BLDG & LICENSING DEPT

**HAMILTON L8P 4Y5** 

Inspection report delivered by email: CITY OF HAMILTON(mgabriel@synagro.com)

SCHINDLER ELEVATOR (tssa.swontario@ca.schindler.com)

(jeffrey.freeman@schindler.com)

(kchristie@synagro.com)

### **INSPECTION NOTES**

Inspection order(s) are issued pursuant to my authority under section 21. (1) of the Technical Standard and Safety Act, 2000.

Failure to comply with inspection orders by the required date may result in this device being removed from service.

NI.			Compliance
No.	Inspection Order(s)	Issued Date	Date
1	ED CAD 3.14.1	Oct 14, 2021	Jan 12, 2022
	The device designation (alphabetical or numerical identification) shall be engraved or painted on the car crosshead or car frame, visible from the point of access.		
	The TSSA installation number shall be permanently posted on the car top, visible from the point of access.		
2	ASME A17.1/CSA B44-10 8.6.1 (CAD)	Oct 14, 2021	Nov 13, 2021
	The in car emergency lighting shall be made operative.		
3	ASME A17.1/CSA B44-10 8.6.1 (CAD)	Oct 14, 2021	Nov 13, 2021
	The emergency alarm shall be operative when activated by the alarm or emergency stop button in the car.		
4	ASME A17.1/CSA B44-10 8.6.1 (CAD)	Oct 14, 2021	Nov 13, 2021
	The two-way communication means shall provide on demand to authorized personnel, information that identifies the building location and elevator number and that assistance is required.		
	This elevator is located in the Biosolids Management building and the recording or message shall reflect this.		
5	OESC 2015 38-085(2)	Oct 14, 2021	Jan 12, 2022
	All receptacles installed in the machine room / machine space shall have Class A ground fault circuit interrupter type protection. One GFCI protecting the others is permitted.		
	Repair or replace the top of shaft machine space receptacle. It is not functioning.		
6	ASME A17.1/CSA B44-10 8.6.1 (CAD)	Oct 14, 2021	Nov 13, 2021
	Provide adequate running clearances between car and hoistway/ counterweight/ counterweight guard.		

#### This report is issued under the Technical Standards and Safety Authority Act, 2000, s. 17 (1)

17. (1) An inspector may conduct an inspection and may, as part of that inspection, enter and inspect at any reasonable time the lands and premises where any of the things, parts of things or classes of things to which this Act, the regulations or a Minister's Min

(a) ensuring compliance with this Act, the regulations or a Minister's order; (b) ensuring that an authorization holder remains entitled to the authorization; or

(c) determining whether a hazardous condition exists. 2006, c. 34, s. 25 (5).



# TECHNICAL STANDARDS and SAFETY AUTHORITY

345 Carlingview Drive Toronto, Ontario M9W 6N9 Toll free 1-877-682-8772 www.tssa.org

## **Inspection Report**

Report No.: 9010133 Report Date: Oct 14, 2021

Inspector: Gilmet, William Phone: 647-459-9665 Email: wgilmet@tssa.org

ISSUED INSPECTION ORDER(S) TO: CITY OF HAMILTON					
No.	Inspection Order(s)	Issued Date	Compliance Date		
	The clearance between the car and the pit ladder is not sufficient.				

This report is issued under the Technical Standards and Safety Authority Act, 2000, s. 17 (1)

17. (1) An inspector may conduct an inspection and may, as part of that inspection, enter and inspect at any reasonable time the lands and premises where any of the things, parts of things or classes of things to which this Act, the regulations or a Minister's order apply are used, operated, installed, made, manufactured, repaired, renovated or offered for sale for the purpose of,

(a) ensuring compliance with this Act, the regulations or a Minister's order; (b) ensuring that an authorization holder remains entitled to the authorization; or

(c) determining whether a hazardous condition exists. 2006, c. 34, s. 25 (5).