



**NOTES :**

1. MINIMUM DEPTH OF BURY 1800mm.
2. BEDDING DETAILS (WM-200.01 & WM-200.02)
3. INSTALLATION DETAILS (WM-207.01)
4. MINIMUM DISTANCE BETWEEN TAPS MAY VARY  
DEPENDENT ON WATERMAIN PIPE MATERIAL  
AND SHALL BE CONFIRMED WITH THE PIPE MANUFACTURER.

- 1 MAIN STOP
- 2 CURB STOP

City of Hamilton  
Public Works Department

**PIPING ARRANGEMENT FOR 19mm OR 25mm DIA. WATER SERVICE  
CONNECTIONS IN A COMMON TRENCH**

DIMENSIONS SHOWN ARE IN MILLIMETRES  
UNLESS OTHERWISE NOTED (N.T.S.)

DATE  
June 2025

REV No  
2

FORMERLY: RWS 702

HAMILTON STD No

**WM-207.02**