


**PLAN VIEW - METER**



**SIDE VIEW**

**NOTES:**

1. METER IS TO BE INSTALLED IN AN AREA SUITABLY HEATED TO PREVENT FREEZE-UPS.
2. THE PROPERTY OWNER SHALL PROVIDE CLEAR ACCESS TO METER AT ALL TIMES.
3. METER SUPPLIED AND INSTALLED BY CITY.
4. SPACER TO BE TEMPORARILY INSTALLED AND METER TO BE INSTALLED BY THE CITY AT A LATER TIME.

		MIN. DIMENSION A (mm)	
		THREADED FITTINGS	SOLDERED FITTINGS
METER SIZE	16	500	450
	20	575	475
	25	600	525
	38 - 50	750	750

City of Hamilton  
Public Works Department

**PIPING FOR RESIDENTIAL 16mm TO 50mm DIA. METER  
FOR INTERNAL INSTALLATION**

DIMENSIONS SHOWN ARE IN MILLIMETRES  
UNLESS OTHERWISE NOTED (N.T.S.)

DATE: DRAFT  
JUNE 2019

REV No  
1

FORMERLY: RWS 715

HAMILTON STD No

**WM-211.03**