



PITOMETER FOR CONCRETE PRESSURE PIPE



PITOMETER FOR STEEL/DUCTILE IRON PIPE

NOTES:

1. IRON PIPE THREAD REQUIRED FOR PITOMETER CONNECTION
2. PROVIDE 150 mm DIA ACCESS IN CHAMBER TOP OF SLAB
3. CORP. STOP MAY BE USED IN PLACE OF BALL VALVE.

City of Hamilton
Public Works Department

PITOMETER CONNECTION FOR STEEL AND CONCRETE PIPE

DIMENSIONS SHOWN ARE IN MILLIMETRES
UNLESS OTHERWISE NOTED (N.T.S.)

DATE
June 2025

REV No
2

FORMERLY: RWS 801

HAMILTON STD No

WM-217