



WATERMAIN LOWERING DETAIL

NOTES:

1. CONTRACTOR TO FOLLOW DESIGN AND ANY CHANGES TO DESIGN REQUIRES PRIOR APPROVAL FROM THE CITY OF HAMILTON
2. NO INTERMEDIATE JOINTS BETWEEN 45° BENDS
3. INSTALL ALL 45° BENDS WITH RESTRAINED JOINTS, PER THE APPROVED PRODUCTS LIST.

City of Hamilton
Public Works Department

INTERCONNECTION FROM WATERMAINS 500mm OR GREATER

DIMENSIONS SHOWN ARE IN MILLIMETRES
UNLESS OTHERWISE NOTED (N.T.S.)

DATE
June 2025

REV No
1

FORMERLY:

HAMILTON STD No

WM-242